

**EC TYPE-EXAMINATION**  
acc. to Pressure Equipment Directive 97/23/EC

Certificate No.: IT01/0324/15

**Name and address of manufacturer:**

**FRIGOR s.r.l.**  
**Via Lavisotto, 10**


**I-38100 TRENTO**

This is to confirm that a representative sample of the type range described below meets the requirements of the Pressure Equipment Directive 97/23/EC.

Examined acc. to Directive 97/23/EC:	EC type-examination (module B)
Test Report No.:	IT05/0323/15 (design) & IT01/0324/15 (inspection)
Description of sample:	Impianto frigorifero con evaporatori ad espansione diretta Refrigeration unit with evaporators in direct expansion matricola N°/ serial no.: 121-15A
Category::	IV
Sample is representative for:	Assemblaggio ed installazione di impianti di refrigerazione ad espansione diretta costruiti sul posto in accordo al disegno n° S.121-15A ed alla lista accessori allegata n° C.121-15A. Assembly and installation of refrigeration unit with direct expansion based on the provisions of drawing no. S.121-15A and equipment list no. C.121-15A.
Drawing No.:	S.121-15A
	Approved drawings are attached.
Remarks / Expiration date:	(1) Design code applied: UNI EN 14276-2:2006 (2) The validity of this type examination is directly coupled to annually performed surveillance based on 97/23/EC Module D, conducted by the Notified Body 0090. (3) The type examination expires on FEB 19, 2025 based on fulfillment of the above mentioned condition, otherwise the validity expires automatically.

Jena, FEB 20, 2015



  
 (U. Sprengholz)  
 Certification Body for Pressure Equipment of  
 TÜV Thüringen e.V.  
 Notified Body 0090 97/23/EC